



Declaration of Conformity

For the following equipment	:

Product Name: Switching Power Supply

Model Designation: NSP-3200-xz (x can be 24 or 48; z can be blank, PM or CAN)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards

were applied:

RoHS Directive (2011/65/EU) 、(EU)2015/863

Low Voltage Directive (2014/35/EU):

EN 62368-1:2014+A11 CB certificate No : DK-126691-UL

Electromagnetic Compatibility Directive (2014/30/EU):

EMI (Electro-Magnetic Interference)

—···· \—·······························				
Conducted emission	EN 55032:2015/A11:2020	Class B		
Radiated emission	EN 55032:2015/A11:2020	Class A		
Harmonic current	EN IEC 61000-3-2:2019			
Voltage flicker	EN 61000-3-3:2013+A1:2019			

EMS (Electro-Magnetic Susceptibility)

EMS (Electro-Magnetic Susceptibility)					
EN 55024:2010+A1:2015	EN 55035:2017/A11: 2020	EN IEC 61000-6-2:2019			
ESD air	EN 61000-4-2:2009	Level 3	8KV		
ESD contact	EN 61000-4-2:2009	Level 2	4KV		
RF field susceptibility	EN IEC 61000-4-3:2020	Level 3	10V/m		
EFT bursts	EN 61000-4-4:2012	Level 3	2KV/5KHz		
Surge susceptibility	EN 61000-4-5:2014/A1:201	7 Level 4	2KV/Line-Line		
Surge susceptibility	EN 61000-4-5:2014/A1:201	7 Level 4	4KV/Line-Earth		
Conducted susceptibility	EN 61000-4-6:2014	Level 3	10V		
Magnetic field immunity	EN 61000-4-8:2010	Level 4	30A/m		
Voltage dip, interruption	EN IEC 61000-4-11:2020 <5% residual voltage for 0.5 cycles ,70% residual voltage for 25 cycles , <5% residual voltage for 250 cycles				

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number TC2xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D:

(Name / Position)

Aries (Signature)

Alex Tsai/Director, Product Strategy Center:

(Name / Position)

(Signature)

Taiwan

Apr. 22nd, 2022

(Place)

(Date)