

EC-Conformity Declaration

For the following equipment :

Product Name: AC/DC Switching Adaptor

Model Designation: GSXAY (X=40 or 60)(Y=05/07/09/12/15/18/24/48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

Low Voltage Directive (2006/95/EC) :

EN60950-1:2006 TUV certificate No : R50127275

Electromagnetic Compatibility Directive (2004/108/EC) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

	EN55022:2006+A1:2007	Class B
	EN55011:2007+A2:2007 (Group 1)	Class B
	EN61000-6-3:2007	
Harmonic current	EN61000-3-2:2006	

Voltage flicker	EN61000-3-3:1995+A1:2001+A2:2005

EMS (Electro-Magnetic Susceptibility)

EN55024:1998+A1:2001+	A2:2003 EN61204-3:2000 EN61000-6	5-1:2007	
ESD air	EN61000-4-2:1995+A1:1998+A2:2001	Level 3	8KV
ESD contact	EN61000-4-2:1995+A1:1998+A2:2001	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006	Level 2	3V/m
EFT bursts	EN61000-4-4:2004	Level 2	1KV/5KHz
Surge susceptibility	EN61000-4-5:2006	Level 3	1KV/Line-Line 2KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2007	Level 2	3V
Magnetic field immunity	EN61000-4-8:1993+A1:2001	Level 2	3A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip 0.5 periods	30% dip 25 pe	eriods >95% interruptions 250 periods
Keyed carrier immunity	ENV50204:1995	Level 2	3V/m 900MHz
Note:			

Note

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

Energy-Related Products Directive (2009/125/EC) :

Ecodesign requirements for no-load condition electric power consumption and average active efficiency of external power supplies EC No.278/2009

This Declaration is effective from serial number EB01xxxxxx

Person responsible for marking this declaration 3

Mean Well Enterprises Co., Ltd.

(Manufacturer Name)

28, Wu-Chuan 3rd Road, Wu Ku Ind. Park, Taipei Hsien, Taiwan R.O.C.

(Manufactures Address)

Johnny Huang/Senior Ventication Engineer (Name / Position)

Red Cheng/Product Manager : (Name / Position)

(Signature)

(Signature)